



TENDER TITLE: SUPPLY AND INSTALLATION OF THE 2 X AIR-CONDITIONERS

ADDENDUM No: 1

ISSUE DATE: 08th June 2021

The Central Bank of Lesotho informs all the proponents of the additional information on the tender as follows:

Description	Original Requirement	New requirement
On Coil Temperature	-	The on-coil temperature is 27°C
Supply Temperature	-	The supply temperature is 14°C
Temperature and humidity control	-	Temperature control is a requirement and no humidification (cooling only).
Delivery Period	Not more than 4 weeks	Not More than 8 weeks

M. Lechela (Mrs.)
Secretary, Tender Committee